

DfI Rivers Lisburn

Pete Gray
Bedford House
16-22 Bedford Street
Belfast
BT2 7FD

Ravarnet House
36 Altona Road
Lisburn, BT27 5QB
Tel: 028 92 606 100

Your ref:
Our ref: IN1-19-9442

Date: 18st August 2020

Dear Pete,

RE: Schedule 6 Application Ref: IN1-19-9442 - Becon Project application for consent to discharge storm water

Thank you for your re-application request dated 12th August 2020 regarding Schedule 6 approval. From a drainage aspect my comments are as follows.

DfI Rivers consents to storm discharge at your total stated maximum attenuated run-off rate of 201l/s from the main site to the undesignated watercourse under the terms of the Drainage (Northern Ireland) Order 1973. This is shown on BCN-ARP-ZZ-XX-DR-CD-0013 submitted with your original application.

DfI Rivers also consents to storm discharge at your total stated maximum attenuated run-off rate of 135.4 l/s from the road to the undesignated watercourses under the terms of the Drainage (Northern Ireland) Order 1973. This consists of three individual discharge locations as shown on drawing no. GE-C-BOG-XX-055 (63.1l/s, 13l/s and 59.3l/s) submitted with your original application.

The Department accepts the outfall submitted with the same application as above and advises that it should be constructed in appropriate scale to the size of the outlet pipe. The discharge pipes and outlet structures should be turned in the direction of flow and anti-scour measures taken to prevent bank and bed erosion.

Attenuation method is to be by using a hydrobrake fitted manhole and appropriate storage systems within the site.

The developer should also satisfy himself that the watercourse downstream from the proposed discharge should be free from obstructions such as silt, weed

growth or debris to provide adequate outfall for storm discharge. This should be brought to the attention of the developer or landowner prior to discharge.

You should note that, in accordance with Paragraph 11 of Schedule 6 of the Drainage (Northern Ireland) Order 1973, any consents/ approvals given by DfI Rivers under Schedule 6 shall not affect the liability of any riparian/developer to comply with other legislation. It is your responsibility to contact any other parties which may have an interest in your proposals e.g. NIEA, Landowners, Fisheries etc.

You are requested to notify DfI Rivers of the commencement date of your works so that an inspection may take place during construction.

In giving its consent the Department would stress that it is your responsibility to ensure that the proposed works do not result in any obstruction to flow arising from blockage, structural failure, poor workmanship or any other reasons.

This consent is valid for a period of 12 months from the date of this letter. If proposals are not completed within this period of time they should be resubmitted for further appraisal.

Please note that the responsibility for the continued maintenance of undesignated watercourses rest with riparian landowners.

Please quote the above reference number in any future correspondence.

Yours sincerely

A handwritten signature in black ink that reads "Jonathan Steenson". The signature is written in a cursive, slightly slanted style.

Jonathan Steenson
Engineering Section